

Bronston Water Association Inc
PO Box 243
Bronston KY 42518
606.561.5209
FAX 606.561.0102

REQUIREMENTS FOR NEW WATER CONNECTIONS:

1. The water line must be buried in a ditch that is at a minimum of 24 inches in depth.
2. The water line must be a minimum of 200 psi.
3. A shut-off valve must be installed.
4. A one-way check valve must be installed.
5. A pressure regulator may be required as prescribed by the utility.
6. There shall be no galvanized pipe or fittings used in the installation.
7. The water line must be visually inspected by the utility.
8. If a well is being used, it must be disconnected, and the utility must inspect to verify separation.

SHUT OFF VALVE:

Effective March 1, 2014 there will be a charge of \$125.00 to replace the meter stop if it has been broken due to excessive turning on and off at the meter. The meter is not to be used as a water shut-off to the home. To avoid this charge, we would recommend that you have a ball valve shut-off placed at the meter for turning off and on.